




TYPE A THRU CURB DRAIN
SECTION A-A



TYPE E THRU CURB DRAIN
SECTION B-B

ASPHALT REPAIR AT GUTTER (TYP)



GENERAL NOTES

1. #4 REBAR DOWELS, 6" MINIMUM DEPTH INTO EXISTING SIDEWALK, CURB & GUTTER. DO NOT DOWEL PRIVATE IMPROVEMENTS INTO PUBLIC IMPROVEMENTS.
2. 4" MINIMUM CLASS 2 A.B. COMPACTED TO 90%
3. 1/2" DEEP CONTRACTION JOINTS AT 20', 1/4" DEEP CONTRACTION JOINTS AT 10'
4. PIPE TO BE EITHER SCH 40 PVC OR CAST IRON
5. ALL CONCRETE SHALL BE 6 SACK 3/4" WITH ONE POUND LAMP BLACK PER CUBIC YARD
FINISH TO BE UNIFORM FINE BROOMED TEXTURE
6. IF TYPE A CURB & GUTTER IS IN GOOD CONDITION, CONTRACTOR MAY CORE DRILL WITH ENGINEER APPROVAL.
7. ASPHALT TO BE HMA 1/2" FINE
8. UNLESS OTHERWISE NOTED, ALL RADII TO BE 1/2"

CITY OF BELMONT DEPARTMENT OF PUBLIC WORKS TYPE A & E CONCRETE THRU CURB DRAIN

DWG No. _____

APPROVED
JAN 2013 NOT TO SCALE